

## FIRE CODE OF NEW YORK STATE

### §F3805 PROHIBITED USE OF LP-GAS

#### §F3805.3 Balconies.

LP-gas containers with a water capacity greater than 2.5 pounds (1.14 kg) shall not be stored on balconies. LP-gas burners having an LP-gas container with a water capacity greater than 2.5 pounds (1.14 kg) shall not be located on balconies or within 10 feet (3048 mm) of combustible construction.

Exception: One-and two-family dwellings.

### §F307 OPEN BURNING

#### §F307.5 Open-flame cooking devices.

Charcoal burners and other open-flame cooking devices shall not be operated on combustible balconies or within 10 feet (3.1 m) of combustible construction.

#### EXCEPTIONS:

1. One-and two-family dwellings.
2. Where buildings, balconies and decks are protected by an approved automatic sprinkler system.

#### §F307.5.1 Liquefied-petroleum-gas-fueled cooking devices.

LP-gas burners having an LP-gas container with a water capacity greater than 2.5 pounds (1.14 kg) [nominal 1 pound (0.454 kg) LP-gas capacity] shall not be located on combustible balconies or within 10 feet (3048 mm) of combustible construction.

EXCEPTION: One-and two-family dwellings.